

Test Report

No. SDHG1308006677FB

Date: Aug.15, 2013

Page 1 of 3

HD SUPPLY FACILITIES MAINTENANCE
10641 SCRIPPS SUMMIT CT SAN DIEGO, CA, 92131 U.S.A.

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description : 3.5" VERTICAL BLINDS
 SGS Ref. No. : GZHG1308028686OT
 Manufacturer : DONGGUAN FANCHANG CURTAIN PRODUCTS CO., LTD.
 Buyer : HD SUPPLY FACILITIES MAINTENANCE
 Country of Destination : U.S.A.
 Other Info. : COLOR:WHITE/ALABASTER
 Sample Receiving Date : Aug.08, 2013
 Test Performing Date : Aug.08, 2013 to Aug.15, 2013

Test Result Summary

No.	Test(s) Requested	Result(s)	Comments
1	NFPA 701 Test Method 2(flat) 2010 Edition: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films	PASS	
For further details, please refer to the following page(s)			

Signed for and on behalf of
SGS-CSTC Co., Ltd.



Ivette Zhang
Approved signatory

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To ensure the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755)83071443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd. | 1F, 1st Building, European Industrial Park, No.1 Shunshan Road, Wusha Section, Daliang Town, Shunde, Foshan, Guangdong, China | 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
 Guangzhou Branch: 10th Floor, Shunde Center Street, Shunde, Guangdong, China | 中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Test Report

No. SDHG1308006677FB

Date: Aug.15, 2013

Page 2 of 3

Test Conducted:

NFPA 701 Test Method 2(flat) 2010 Edition: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films

Sample Details

Name / Color:	3.5" VERTICAL BLINDS / White
Weight:	1.08 kg/m ²

Test Results:

Original State tested to Chapter 15 of NFPA 701-Method 2 for Flat

Specimen	Char Length (Inches)	After flame (Seconds)	Flaming Residue (Seconds)	Rating
1	6.2	0	0	Pass
2	5.3	0	0	Pass
3	5.8	0	0	Pass
4	6.0	0	0	Pass
5	6.3	0	0	Pass
6	5.5	0	0	Pass
7	4.7	0	0	Pass
8	5.3	0	0	Pass
9	4.5	0	0	Pass
10	5.8	0	0	Pass

Remark:

(1) The specimen length parallel to the lengthwise direction of the material.

Requirements:

1. The time of individual specimen continues flaming was not more than 2 seconds after the test flame is removed from contact with the specimen.
2. The length of char of any single flat specimen does not exceed 435 mm (17.1in).
3. The time of portions or residues continues flaming was not more than 2 seconds.

Note:

As per the standard requirement, the sample size were 125×1200±22mm, but the client did not submit suitable size, so as per the client's requirement, the submitted sample overlap and staple.

Conclusion:

The submitted sample met the requirements of NFPA 701 Test Method 2-2010 Edition.

To be continued...

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To ensure the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755)83071443, or email: CN.Doccheck@sgs.com

SGS-CSTI Standards Technical Services Co., Ltd. 1F, 1st Building, European Industrial Park, No.1 Shunshen Road, Wusha Section, Daling Town, Shunde, Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
 Guangzhou Branch: 10/F, 10th Floor, Guangzhou Center, Shunde Shengze Laboratory, 中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Photo Appendix:



End of Report

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To ensure the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755)83071443, or email: CN.Doccheck@sgs.com