

# WARNING!

- DO NOT OVER FILL** - Fill by scale only. Maximum allowable gross weight = .8 x water capacity (W.C.) + cylinder tare weight (T.W.). It is illegal to transport an overfilled cylinder. Overfilling can lead to violent cylinder rupture causing serious personal injury or death.
- DO NOT OVERPRESSURIZE** - Do not connect to a pressure source in excess of marked rating on cylinder. Excess pressure can cause cylinder bursting.
- Store in a cool, dry place. Do not expose to temperatures in excess of 120 F.
- Only trained technicians should attempt to recover refrigerant from a system into a container.
- Be sure all connections are made tight before transferring refrigerant to container.
- Do not leave container unattended while transferring refrigerant.
- Do not fill with flammables, corrosives or toxic content. Do not mix refrigerant gases.
- Refrigerant gas is an asphyxiant. Only transfer gas in a well ventilated work space. Refrigerant can displace oxygen available for breathing. Avoid inhaling gases.
- Liquid refrigerant can cause frostbite. Avoid contact with skin.
- Steel cylinders must be periodically inspected for corrosion or handling damage.
- Filled cylinders must be properly labeled for transportation. Cylinder user should be familiar with all Department of Transportation (DOT) regulations and Air Conditioning and Refrigeration Institute (ARI) guidelines.
- LIMITS ON REFILL** - It is illegal to refill this cylinder more than five years after the Retest Date stamped on the handle (five years after date of manufacture) unless this cylinder has been found free of defects following a visual inspection of both inner and outer surfaces by a qualified tester. Proof of inspection must be marked on the handle. A cylinder showing evidence of corrosion or other defects that can potentially weaken the cylinder appreciably may not be refilled and must be destroyed. The relief valve must be tested on the Retest Date and replaced if defective. **IT IS ILLEGAL TO REFILL THIS CYLINDER AFTER THE LAST PERMISSIBLE REFILL DATE STAMPED ON THE HANDLE.**

Mfd for YSN Cylinders, Gardena, CA 90249